



EC DECLARATION OF CONFORMITY

FTVAA Wall Humidity/ Temperature Sensor
FTVAK Duct Humidity/ Temperature Sensor

We certify that the apparatur detailed above conforms with the protection requirements of The Electromagnetic Compatibility Directive as below by application of the following Harmonised Standards and when installed and operated in accordance with current relevant installation and operational standards and practices together with any additional information contained in the data sheet and/or manual, to following standards:

Normative references

- 2004/108/EC** Electromagnetic Compatibility and reapiling to Directive 89/336/EEC
- EN 61326-1:2006** Electrical equipment for measurement, control and laboratory use
EMC requirements – General requirements
- EN 61326-2-3:2006** Electrical equipment for measurement, control and laboratory use
EMC requirements – Particular requirements
Test configuration, operational conditions and performance criteria
for transducers with integrated or remote signal conditioning

Date of issue
Signed:

14th February.2014
Ewert Johansson


Managing Director